



Transmission Company of Nigeria

MEMORANDUM

Date:.....6TH December 2022

From:.....ED(TSP)

To:.....MD/CEO(TCN)

sir

FORCE MAJEURE DECLARATION AS A RESULT OF DESTROYED 132KV TOWER IN ABUJA CENTRAL AREA

On Tuesday 6th November 2022 at about 1455hrs, a transmission tower in circuit at central area Abuja was severely damaged by a running truck that ran out of control over the tower no.20

The incident resulted into a complete shutdown of Katampe 132/33kV station and GIS station in the central area.

The impact on the damage tower affected a nearby 33kV feeder, thereby curtailing all supply to and from the two stations mentioned above.

The total load recorded before the incident as the last hour reading was 37.2MW.

As a result of this unfortunate and unforeseen incident, TCN-TSP is regrettably declaring a Force Majeure in accordance with the provision of the Market Rules in section 46.8.4(d)

However, to alleviate the impact of the incident that resulted in the declaration of this Force Majeure, an immediate assessment of the situation was made as soon as the event came to the notice of the management and the environment was cleared of all dangerous circumstances.

Jumpers were removed at critical points to enable power supply to Katampe since yesterday at 2140hrs of 06-12-2022, Katampe -Apo 132kv lines 1&2 were restored.

Secondly Katampe lines 1&2 have been worked on to back feed areas under GIS central area station. Furthermore, a hunt for suspension tower has since started and still going as soon as it is found, the damage tower will be earnestly replaced and normal supply arrangement will be in place.

All stakeholders affected would be updated regarding the Force Majeure event as the situation improves or changes in accordance with the provision of the market Rules 46.8.4(h).

Secondly, Katampe lines 1&2 have been worked on to back feed areas under GIS central area station. Furthermore, a hunt for suspension tower has since started and still going as soon as it is found, the damage tower will be earnestly replaced and normal supply arrangement will be in place.

All stakeholders affected would be updated regarding the Force Majeure event as the situation improves or changes in accordance with the provision of the Market Rules 46.8.4(h).

Please accept the assurance of our highest regards.



ENGR, G.V. ADEWUNMI

ED (TSP) (TCN).

Cc: MO

: SO

: P.Aff✓

